

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0067:235

Page 1 of 1

**CATEGORY:** Audible Signal Devices

**LISTEE:** Siemens Building Tech/Fire Safety Division, 8 Fernwood Rd., Florham Park, NJ 07932  
Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

**DESIGN:** Models U-HN-AC, U-HN-AC-W, U-HN, U-HN-W, U-HNH, and U-HNH-W electronic horns; Models U-HN-S17-1, U-HNH-S17-1, U-HN-S110-1, and U-HNH-S110-1 horn strobes with suffix -C, or -W; Models U-HN-S17-1-AC, U-HN-S110-1, U-HNH-S17-1, and U-HNH-S110-1 horn strobes with suffix -C or -W. Models with suffix -S17S or -S110S are synchronized strobes and must be used with Models SCM-F or DSC (CSFM Listing No. 7300-0067:212) sync module. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** With suffix -S17 = (68cd)  
With suffix -S110 = (100cd)

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Models are suitable for outdoor use when used with Models FWB-1, -1W or FWB-2, FWB-2W back box.

**MARKING:** Listee's name or Siemens, model number, electrical rating and UL label.

**APPROVAL:** Listed as horns and horn/strobes for use with separately listed compatible fire alarm control units. These devices are not approved for hearing impaired applications. Refer to manufacturer's Installation Manual for details.

**NOTE:** If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal.

**XLF:** 7135-0065:162

03-26-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**